



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	July 27, 2007	Interpretation	06-114
Topic	Commercial Alarm Combo Panel		
Code Section(s)	NFPA 72 (2002) 6.8.4.1 CFC (2001) 1006.3.2		
Requested by	Raymond Wilson ADT Security Services, Inc. 6837 Hayvenhurst Avenue Van Nuys, CA 91406 <a href="mailto:raywilson@ADT.com">raywilson@ADT.com</a>		

**Question: Can a combination Fire Alarm and Burglar Alarm System be installed in California?**

Yes, a combination Fire Alarm and Burglar Alarm System can be installed in California as long as the fire alarm control unit and all connected devices are listed and approved for the purpose of which they are installed by the California State Fire Marshal and approved by the local jurisdiction.